

Clinical Laboratory of San Bernardino, Inc.
Celebrating 50 Years of Analytical Service 1967-2017



Indian Creek - Westridge CSD
 P.O. Box 952
 Bishop CA, 93515

Project: Routine
 Sub Project: Annual & Well 3 Quarterly Iron
 Project Manager: Terry Tye

Work Order: 19F1963
 Received: 06/25/19 09:26
 Reported: 07/02/19

Well 1		19F1963-01 (Water)				Sample Date: 06/24/19 12:40		Sampler: Terry Tye	
Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier

General Chemical Analyses

Nitrate as N (NO3-N) EPA 300.0 **0.69** 0.40 10 mg/L 06/25/19 06/25/19 1926056

Semi-Volatile Organic Analyses / EPA 504

Ethylene Dibromide (EDB) EPA 504.1 ND 0.020 0.05 ug/L 06/28/19 07/01/19 1926140

Dibromochloropropane (DBCP) EPA 504.1 ND 0.010 0.2 ug/L 06/28/19 07/01/19 1926140

Well 2		19F1963-02 (Water)				Sample Date: 06/24/19 12:45		Sampler: Terry Tye	
Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier

General Chemical Analyses

Nitrate as N (NO3-N) EPA 300.0 **1.4** 0.40 10 mg/L 06/25/19 06/25/19 1926056

Semi-Volatile Organic Analyses / EPA 504

Ethylene Dibromide (EDB) EPA 504.1 ND 0.020 0.05 ug/L 06/28/19 07/01/19 1926140

Dibromochloropropane (DBCP) EPA 504.1 ND 0.010 0.2 ug/L 06/28/19 07/01/19 1926140

Well 3		19F1963-03 (Water)				Sample Date: 06/24/19 12:30		Sampler: Terry Tye	
Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier

General Chemical Analyses

Nitrate as N (NO3-N) EPA 300.0 **3.3** 0.40 10 mg/L 06/25/19 06/25/19 1926056

Metals

Iron (Fe) EPA 200.7 ND 100 300 ug/L 06/28/19 06/28/19 1926152

Semi-Volatile Organic Analyses / EPA 504

Ethylene Dibromide (EDB) EPA 504.1 ND 0.020 0.05 ug/L 06/28/19 07/01/19 1926140

Dibromochloropropane (DBCP) EPA 504.1 ND 0.010 0.2 ug/L 06/28/19 07/01/19 1926140

Well 5		19F1963-04 (Water)				Sample Date: 06/24/19 12:50		Sampler: Terry Tye	
Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier

General Chemical Analyses

Nitrate as N (NO3-N) EPA 300.0 **0.41** 0.40 10 mg/L 06/25/19 06/25/19 1926056

Semi-Volatile Organic Analyses / EPA 504

Ethylene Dibromide (EDB) EPA 504.1 ND 0.020 0.05 ug/L 06/28/19 07/01/19 1926140

Dibromochloropropane (DBCP) EPA 504.1 ND 0.010 0.2 ug/L 06/28/19 07/01/19 1926140

